

Prepared by: Y. Makdisi
Y. Makdisi

Date: 2/6/14

Reviewed LP: Y. Makdisi
Y. Makdisi

Date: 2/6/14

ESRC Walk through Check-Off List for PHENIX for Run 14
January 21, 2014

Attending: D. Beavis, C. Biggs, M, Cubillo, M. Gaffney, D. Lynch, Y. Makdisi, P. Sampson, D. Phillips, M. Van Essendelft

Legend:

- ESRC – Experiment Safety Review Committee, Yousef Makdisi
- EC – Experiment Coordinator, Ed O'Brien
- LE – Liaison Engineer, David Phillips
- LP – Liaison Physicist, Yousef Makdisi
- MCRGL- Main Control Room Group Leader, Peter Ingrassia

Checklist Item #	Initial	Title *	Description Of Check-Off List Item	Priority
CK-PHENIX-14-01		ESRC	All relevant ESRC action items closed.	Pre start
CK-PHENIX-14-02		LE	IR: Dumb Waiter inspection date due end of January	Pre start
CK-PHENIX-14-03		EC	IR: Either remove the temporary plastic hoses or use fasteners other than cable ties.	Pre start
CK-PHENIX-14-04		EC	IR: Install fire wire on the MPC racks	Pre start
CK-PHENIX-14-05		EC	IR: Need additional plastic covers to the MPC Low voltage connections.	Pre start
CK-PHENIX-14-06		EC	IR: Look to mitigate the open rack doors due to interference from cables.	Post start
CK-PHENIX-14-07		EC	GMH: Remove the TEC xenon recovery system.	Post Start
CK-PHENIX-14-08		EC	GMH: Remove the plastic line labeled DC CO2.	Post Start
CK-PHENIX-14-09		MCR GL	Check off list is complete	Pre start