

Memo

date: January 13, 2016

to: Thomas Roser

from: Yousef Makdisi (On behalf of the ESRC)

subject: Recommendation for approval to introduce flammable gas into the PHENIX
Detector.

The PHENIX detector was submitted to an Annual Safety Review on December 21, 2015. The Walkthrough was carried out on January 11, 2016. The PASS flammable gas detectors and IR ventilation fans have been certified and the Blue sheeting was completed and signed off. The crane is locked. A shift crew is in place.

With this, approval is requested to introduce flammable gas into the PHENIX detector systems.

Approved: _____

Date: _____

Yousef Makdisi
1/13/2016

cc:

B. Mueller
M. Chiu
A. Poblaguev
D. Phillips
P. Pile
Y. Akiba

File