



Prepared by: 
Y. Makdisi

Date: 2/6/14

Reviewed LP: 
W. Meng

Date: 2/6/2014

ESRC Walk through Check-Off List for STAR for Run 14
January 29, 2014

Attending: W. Christie, Y. Makdisi, A. Pendzick, D. Phillips, R. Soja, M. Van Essendelft

Legend:

ESRC – Experiment Safety Review Committee, Yousef Makdisi
EC – Experiment Coordinator, William Christie
LE – Liaison Engineer, Al Pendzick
LP – Liaison Physicist, Wuzheng Meng
MCRGL- Main Control Room Group Leader, Peter Ingrassia

Checklist Item #	Initial	Title *	Description Of Check-Off List Item	Priority
CK-STAR-14-01		ESRC	All relevant ESRC action items closed.	Pre start
CK-STAR-14-02		EC	IR: Move the HFT installation rails that are blocking access to an electrical panel	Pre start
CK-STAR-14-03		EC	IR: House keeping near the HFT racks	Pre start
CK-STAR-14-04		EC	IR: Assure the HFT racks are bonded	Pre start
CK-STAR-14-05		EC	IR: Rack IB5, add a plastic cover on the high current connections or a relevant sign on the door that should remain closed.	Pre start
CK-STAR-14-06		EC	IR: Bond the Cal North platform rack.	Pre start
CK-STAR-14-07		EC	IR: Assure the FMS racks are bonded	Pre Start
CK-STAR-14-08		EC	AB: House keeping to clear blocked electrical panels	Post Start
CK-STAR-14-09		MCR GL	Check off list is complete	Pre start