

Linac Status

D. Raparia

April 7, 2015
Time Meeting

Status

- Linac running in good condition for polarized proton and BLIP.
- OPPIS is getting stable with time.
- BLIP average current is back to 115 μA with circular beam size.
- Thursday, ground fault at linac, we checked every thing , we could but did not find the fault (45 min)
- Saturday night, water pump for linac cooling tower trip (3.5 HRS)
- Maintenance (04/01/2015):
 - OPPIS, ionizer change
 - Tube 7651 mod 5
 - Tube 8616 mod 3
 - Tube 4pr250 for H- extractor

Average Current and Beam on HRS for BLIP

