

RHIC
CRYOGENICS SYSTEM
Time meeting
5-24-2016

May 20. 56MHz, IP4

- 3:37am Beam permit pulled by 56MHz
 - Cavity quenched. Pressure spiked and pressure stayed level at 14.7 psia. Burstdisk went.
- 3:39am ODH alarm
- 3:46am ODH alarm cleared
- 4:02am Fire dept enters
- 4:45am Fire dept exits and gives okay
- 4:50am Cryo access
- 6:00am Cryo finished burst disk replacement
- 6:45 am CAS sweep sector 4

